## How to Repair a "NAIAD" Cartridge with Dashpot and Oscillating Handle


- 1. To uncover operating cartridge on urinal valves with non-sag handles, unscrew bonnet (386-010) and remove entire assembly (386-010K), on self-closing stops as shown on right hand drawing, first loosen and remove bonnet and oscillating lever by unscrewing bonnet with wrench.
- 2. Either cartridge can now be removed from body by loosening cap (618-001) with a flat wrench and lifting entire cartridge from body including the dashpot.
- 3. If leakage is occurring through spout outlet, insert 1/8" diameter pin or pin wrench (244-025) through hole in stem and with crescent wrench remove stem nut (333-097) and all parts up to and including (1-027) seat. Inspect seat washer (244-006) and replace if necessary, next inspect seat (1-027) for nicks or water cutting and replace if necessary. If cup washer (333-040) has been sticking in dashpot, replace also.
- 4. If cartridge has been leaking between oscillating lever and upper cap, remove stem assembly (386-008K) and spring (395-018) from sleeve (386-014) and cap (618-001) by taking out washer (319-012) from cap, take out packing arrangement which consists of (2) o-rings (319-140) with (1) leather washer (319-035) between o-rings. Grease stem lightly around packing area and put new o-rings and packing on stem using same arrangement as indicated, also lubricate O,D, of packing.
- 5. Place stem with spring, washer, and packing properly assembled back into cap and sleeve. Now assembly lower cartridge parts in proper relation and insert pin or pin wrench (244-025) in stem hole again and tighten nut (333-097).
- 6. We recommend removing and replacing (1-043) gasket before cartridge is placed in valve body. Place cartridge in body and lock cartridge by tightening cap (618-001) securely, add upper cap and oscillating lever sub-assembly to cartridge.

## NOTE:

Fittings using (333-073K) dashpot, follow procedures on page 10 for adjustments.


386 XSLO


(22)



## NOTE: COMPLETE ASSEMBLY OF 386X-SLO UNIT AND 386-010K OSCILLATING LEVER HANDLE ASSEMBLY FOR URINAL VALVES.

ITEM NO.	PART NO.	DESCRIPTION
1	386-008K	BUTTON AND STEM ASSEMBLY
2	395-018	SPRING
3	319-012	BRASS WASHER
4	319-140	O-RING
5	319-035	LEATHER WASHER
6	618-001	BONNET
7	1-043	GASKET
8	433-042	SLEEVE
9	1-027	MONEL SEAT
10	244-006	RUBBER SEAT WASHER
11	333-026	RETAINER
12	333-040	RUBBER WASHER
13	333-039	WASHER
14	1-031	STEM WASHER
15	333-097	STEM NUT
16	333-073K	SLOW DASHPOT ASSEMBLY
17	386-010	BONNET
18	386-009	BALL HANDLE
19	386-011	PLUNGER
20	386-013	SPRING
21	386-014	SLEEVE
22	386-010K	HANDLE ASSEMBLY





## NOTE: COMPLETE ASSEMBLY OF 386X UNIT AND OSCILLATING LEVER AND BONNET FOR SELF-CLOSING STOPS.

ITEM NO.	PART NO.	DESCRIPTION
1	386-007K	BUTTON AND STEM ASSEMBLY
2	395-018	SPRING
3	319-012	BRASS WASHER
4	319-140	O-RING
5	319-035	LEATHER WASHER
6	618-001	BONNET
7	1-043	GASKET
8	433-042	SLEEVE
9	1-027	MONEL SEAT
10	244-006	RUBBER SEAT WASHER
11	333-026	RETAINER
12	333-040	RUBBER WASHER
13	333-039	WASHER
14	1-031	STEM WASHER
15	333-097	STEM NUT
16	333-075	DASHPOT
17	386-009	BALL HANDLE
18	386-005	BONNET

386 X