



T&S BRASS AND BRONZE WORKS, INC.

2 SADDLEBACK COVE / P.O. BOX 1088 / TRAVELERS REST, SC 29690

PHONE 800-476-4103

FAX 864-834-3518



REG. #A2601
ISO #9001

Model No.

B-0183



Item No.:

Job Name:

Architect/Engineer Approval:

Notes:

EPAct2005 NON-COMPLIANT



3 BOLT HOLES 1/2" X 3" HEX HEAD BOLTS & EXPANSION SHIELDS FURNISHED

- NOTE:
1. ASSEMBLY CONNECTS TO 1/2" PIPE NIPPLES ROUGHED IN FROM FLOOR ON 2" CENTERS TO A HEIGHT OF 6".
 2. STANCHION IS BRASS WITH POLISHED CHROMIUM PLATED FINISH.
 3. STANDARD HOSE LENGTH=108" OTHER HOSE LENGTHS AVAILABLE
 4. ASSEMBLY FURNISHED WITH CHECK VALVES TO PREVENT CROSS FLOW OF WATER.
 5. EXTRA CLEARANCE IS PROVIDED BY USING LONGER NIPPLE AT POINT "Y-Y" SHOWN ABOVE.

Product Description:

KETTLE KADDY ASSEMBLY WITH CONTINUOUS PRESSURE VACUUM BREAKER AT HOSE CONNECTION

Drawn:

RJK

Approved

JHB

Checked

JRM

Scale:

1 : 8

Date:

1/4/06