



T&S BRASS AND BRONZE WORKS, INC.
 2 SADDLEBACK COVE / P.O. BOX 1088 / TRAVELERS REST, SC 29690
 PHONE 800-476-4103 FAX 864- 834-3518



Model No.

B-CVH-3/8

Item No.:


REG.#A2601
ISO #9002

Job Name:

Architect/Engineer Approval:

Notes:

3/8" NPT FEMALE INLET



3/8" NPT FEMALE OUTLET

NOTES:

1. MAXIMUM PRESSURE 400 PSI AT 200° F
2. NOT TO BE USED FOR NATURAL GAS APPLICATIONS.

Product Description:

HORIZONTAL CHECK VALVE FOR WATER USE ONLY
 WITH 3/8" NPT INLET & OUTLET

Drawn:

WJS

Approved

MVW

Checked

ARY

Scale:

1' = 1'

Date:

8-13-97