

T&S BRASS AND BRONZE WORKS, INC.  
 2 SADDLEBACK COVE / P.O. BOX 1088 / TRAVELERS REST, SC 29690  
 PHONE 800-476-4103 FAX 864- 834-3518



Sales No.




FLOW TOWER

Item No.:

Job Name: ST. JOHN'S HEALTH CENTER  
 REPLACEMENT PROJECT

Architect/Engineer Approval:

Notes:



FLOW HOLDER IS THEN SECURELY  
 PRESSED INTO A CIRCULAR RECESS  
 IN BOTTOM OF BARREL



FLOW TOWER IS SECURELY  
 PRESSED INTO FLOW HOLDER.  
 REFER TO CHART BELOW FOR FLOW  
 RATE OPTIONS

COMPLETED ASSEMBLY

FLOW RATE ( GPM )	SUFFIX
0.25	-03
0.40	-05
0.70	-07
0.90	-10
1.20	-12
1.40	-15
2.00	-20
2.50	-25

Product Description:

ETERNA BARREL w/ FLOW CONTROL

Drawn:

WJS

Approved

Checked

Scale:

1 : 1

Date: