



T&S BRASS AND BRONZE WORKS, INC.  
 2 SADDLEBACK COVE / P.O. BOX 1088 / TRAVELERS REST, SC 29690  
 PHONE 800-476-4103 FAX 864- 834-3518



Model No.

B-0199-03F

Item No.:


Job Name:

Architect/Engineer Approval:

Notes:

FLOW CONTROL TOWER  
 (SPECIFY FLOW DESIRED  
 FROM CHART BELOW)

13/16-27 MALE  
 THREADS



NOTE: SELECT FLOW CONTROL DESIRED & ADD SUFFIX TO MODEL NO.

FLOW (GPM±15%)	SUFFIX	SPECIFY
0.25	-03	B-0199-03F-03
0.40	-05	B-0199-03F-05
0.70	-07	B-0199-03F-07
0.90	-10	B-0199-03F-10
1.20	-12	B-0199-03F-12
1.40	-15	B-0199-03F-15
2.00	-20	B-0199-03F-20

Product Description:

FLOW CONTROL AERATOR W/ 13/16-27 MALE THREADS

Drawn:

TME

Checked

MVW

Scale:

1' = 1'

Approved

MVW

Date:

2/3/00